



NOTES:

1. PRIOR TO EXECUTING WALL FLASHING DETAIL REFER TO APPROPRIATE UNIFLEX PREMIUM ELASTOMERIC SPECIFICATION.
2. WIDTH OF POLYESTER FABRIC IS DETERMINED BY HEIGHT OF PARAPET WALL OR THE LOCATION OF EXISTING TERMINATION BAR. UTILIZE 12" OR 40" WIDTH POLYESTER FABRIC.
3. REFER TO SPECIFICATIONS FOR REQUIRED COVERAGE RATES.



UNIFLEX PREMIUM ELASTOMERIC SYSTEM

TYPICAL WALL FLASHING DETAIL

DATE: 3/25/11

SHEET NO:

WF-1

NOT TO SCALE